



CITY OF LAS VEGAS  
DEPARTMENT OF BUILDING & SAFETY  
PERMIT APPLICATION

BAR CODE HERE

TYPE OR PRINT (BLACK INK ONLY)

Project # 169109-C-10

Parent Project # 119565

FOR: ☒ Commercial & Public Structures ☐ Single Family Residence

WORK DESCRIPTION: DRAG BEAM NCRs, MUSEUM PROJECT

PERMITS REQUESTED: ☐ Building ☐ Mechanical Val ☐ Plumbing Val ☐ Electrical Val

TOTAL VALUATION: \$ \_\_\_\_\_

ADDRESS: 300 STEWART AVE ZIP \_\_\_\_\_

OWNER/BUILDER NAME: CITY OF LAS VEGAS

CONTRACTOR: APCO CONSTRUCTION

PROJECT/BUSINESS NAME: \_\_\_\_\_

CONTACT PHONE NO.: 702-366-1836 CONTACT FAX NO.: \_\_\_\_\_

STATE CONTRACTOR LICENSE NO.: 14589 CITY BUSINESS LICENSE NO.: \_\_\_\_\_

PARCEL NO.: \_\_\_\_\_ ZONE: \_\_\_\_\_

LOT(s): \_\_\_\_\_ BLOCK: \_\_\_\_\_ SUBDIVISION: \_\_\_\_\_

OCCUPANCY GROUP: \_\_\_\_\_ USE: \_\_\_\_\_ CONST. TYPE: \_\_\_\_\_

SQUARE FT OF FLOOR AREAS: 1<sup>st</sup> \_\_\_\_\_ 2<sup>nd</sup> \_\_\_\_\_ 3<sup>rd</sup> \_\_\_\_\_ Garage \_\_\_\_\_

Patio \_\_\_\_\_ Balcony \_\_\_\_\_ Total \_\_\_\_\_ No. of Units \_\_\_\_\_ No. of Stories \_\_\_\_\_

SPECIAL CONDITIONS: \_\_\_\_\_

I state that the information I have supplied on this application is true and correct. By signing this application, I agree to comply with all conditions as noted on this permit.

Contractor or Agent / Owner \_\_\_\_\_ Date \_\_\_\_\_

Planning Department [Signature] Date 8/4/10

Land Development/Flood Control Engr. \_\_\_\_\_ Date \_\_\_\_\_

Fire Department \_\_\_\_\_ Date \_\_\_\_\_

[Signature] 08/12/10  
Building Department \_\_\_\_\_ Date \_\_\_\_\_

TOTAL PERMIT FEE: \$ 125.

PRE-PAID: Plan Review \$ \_\_\_\_\_

PRE-PAID: Zoning \$ \_\_\_\_\_

TOTAL \$ \_\_\_\_\_

**Permit Expires 180 Days After  
Abandonment of Work**

Permits expire when no inspection has been requested for any 180-day period after the permit has been issued.



## CONTACT SHEET

All plan submittals shall include this form.

Call Roger Quinn at 709 366-1836 when plans are ready.

Application # 169109 Fax # 366-0537 PC # 119 565

OWNER / DEVELOPER		PHONE	
ADDRESS		E-MAIL	
ZIP		FAX	
ARCHITECT		PHONE	
ADDRESS		E-MAIL	
ZIP		FAX	
STRUCTURAL ENGINEER		PHONE	
ADDRESS		E-MAIL	
ZIP		FAX	
CIVIL ENGINEER		PHONE	
ADDRESS		E-MAIL	
ZIP		FAX	
CONTRACTOR		PHONE	
LICENSE #		E-MAIL	
ADDRESS		FAX	
ELECTRICAL ENGINEER / CONTRACTOR		PHONE	
LICENSE #		E-MAIL	
ADDRESS		FAX	
MECHANICAL ENGINEER / CONTRACTOR		PHONE	
LICENSE #		E-MAIL	
ADDRESS		FAX	
PLUMBING ENGINEERING / CONTRACTOR		PHONE	
LICENSE #		E-MAIL	
ADDRESS		FAX	



3432 N. 5th Street  
N. Las Vegas, NV 89032

Phone: 702-734-0198  
Fax: 702-734-0396

## REQUEST FOR INFORMATION

No. 00484

**TITLE:** NE Area Well Wall.

**DATE:** 6/23/2010

**PROJECT:** Las Vegas Museum - Phase III

**TO:** Attn: Richard Sourbrine  
Westlake Reed Leskosky  
One East Camelback Rd., Ste 690

**Job Number :** PWP# CL-2009-130

**Project Number :** 08.15341.04-LED

**Apco Job Number :** 0176

**STARTED:**

**COMPLETED:**

**REQUIRED:** 7/3/2010

Phoenix, AZ 85012

Phone: 602-212-0451 Fax: 602-212-1020

### QUESTION:

APCO received a City of Las Vegas Violation for the following.

Detail 212/SB-501 does not depict epoxy dowel tie in from the existing area well wall to the new wall reinforcing.


CSI utilized #6 rebar @ 12oc with an embedment depth of 8".

Please confirm that this is acceptable.

We will need (4) wet stamped copies.

### ANSWER:

EPOXY DOWELS ARE NOT REQUIRED AT THIS  
INTERFACE. THE CONNECTION SUGGESTED IS  
ALSO ACCEPTABLE



**DATE:**

**EXP:**

JUN 30 2010

JUN 30 2012

Requested By: APCO Construction

**CLV**

Date: 6/23/2010

Signed: \_\_\_\_\_

Brian Benson

169109-C-10

119565-C-08

169109

RF 484

**City of Las Vegas**  
**INSPECTION RESULT**  
**AP #: 119565**



**Inspection Date:** 6/23/2010 10:54:00 AM

**Inspector:** ROBERT RANDOLPH

**A/P Name:**  
CITY OF LAS VEGAS MUSEUM

**Inspection Type:**  
160 - (EPOXY EXPRESS)

**Job Address:**  
300 STEWART AVE LAS VEGAS, 89101-

**AP Issued To:**  
APCO CONSTRUCTION

**Location:**

**Comments:**

HOUSE PADS OK. BEAM CONNECTION PLATES @ 1ST FLOOR ELEVATOR SHAFT  
INSTALLED PER ENGINEERING. RECEIVED CHECK # 17776 AND 17777 FOR 100.00 EACH  
FROM APCO CONSTRUCTION.

P  
A  
R  
T  
I  
A  
L  
\*  
P  
A  
S  
S

**Problem/Violations**

AT EAST STAIRWELL RETAINING WALL EXTENTION 1-#4 AND 1-#6 REBAR DOWEL WERE  
INSTALLED 12" OC AT A DEPTH OF 8" WITH HILTI 150 EPOXY. ENGINEERING REQUIRED TO  
MATCH.

## REQUEST FOR INFORMATION

No. 00481

**APCO**  
CONSTRUCTION  
3432 N. 5th Street  
N. Las Vegas, NV 89032

Phone: 702-734-0198  
Fax: 702-734-0396

TITLE: NCR-2b-NCR-13 NE Corner Ramp/Stairs

DATE: 6/21/2010

PROJECT: Las Vegas Museum - Phase III

TO: Attn: Richard Sourbrine  
Westlake Reed Leskosky  
One East Camelback Rd., Ste 690

Job Number : PWP# CL-2009-130

Project Number : 08.15341.04-LED

Apco Job Number : 0176

STARTED:

COMPLETED:

REQUIRED: 7/1/2010

Phoenix, AZ 85012

Phone: 602-212-0451 Fax: 602-212-1020

## QUESTION:

Please see the attached NCR.

The footings located for the exterior ramp located at the North Eassdt side of the structure has limited details and references to the structural drawings. This NCR was issued due to the footing not being designated in accordance with the footing schedule located on 201/SF-501.

APCO and CSI used the most stringent information extracted from the details provided.

Please confirm that it is acceptable to utilize (3) #5 continuous for the 2'-0"x10" thick footings for the ramp walls.

Please provide (4) wet stamped copies.


## ANSWER:

TITE FOOTING SIZES ARE SHOWN ON  
220/SB-502. USE (3) #5 CONT BARS  
ON 220/SB-502.

PLANS APPROVED  
STRUCTURAL  
Building & Safety Dept.  
City of Las Vegas, Nevada

LTB AUG 11 2010

Does Not Include Electrical, Architectural  
Plumbing/Mechanical or Off-Site  
Improvements. Make No Change  
Without Approval. Plan is  
Not a Permit to Violate Any Ordinance.



RECEIVED

AUG 04 2010

CITY OF LAS VEGAS  
PERMITS

DATE:

EXP:

JUN 30 2010 JUN 30 2012

Requested By: APCO Construction

Date: 6/21/2010

Signed:

Brian Benson

CLV

169109-C-10 119565-C-09

**Ningo & Moore**

109/109  
**NON-COMPLIANCE REPORT**

RF  
481

REPORT NO. 2b-NCR-13

DATE 6-21-10

DAY Monday

AUTHOR M. Collins

PROJ. NAME Las Vegas Museum

PROJ. NO. 301777009

CLIENT CLV

CONTRACTOR Apco/CSI

PERMIT NO. 119565

ADDRESS 300 E. Stewart

TYPE OF INSPECTION Reinforced Concrete

AREA INSPECTED Ramp Wall FTG's @ 12 to 14/A to B

The following items of work were found to be in non-compliance with the project plans and specifications:

Plans do not state what size bars are cont. in bottom of FTG for ramp wall FTG in area listed above. 6 on SB-102 and 220 on SB-502 are used for this area. Contractor placed (3) #5 cont. for 2'-0" wide x 10" min thick FTG's. Engineer need to approve the use of #5 bars for cont. FTG to clear NCR.

Ref: 2b-29 for rectify; SB-102 (6) + SB-502 (220)

Work should not proceed in this area until the appropriate corrections have been made and documented.

THIS NOTICE DELIVERED TO GENERAL CONTRACTOR AT \_\_\_\_\_

☐ A.M. ☐ P.M.

BUILDING DEPARTMENT INFORMED BY TELEPHONE AT \_\_\_\_\_

☐ A.M. ☐ P.M.

PROJECT MANAGER/SPECIAL INSPECTOR

SIGNATURE


Michael Collins

PRINT NAME

\*\*\*\*\*  
 \*\*\* TX REPORT \*\*\*  
 \*\*\*\*\*

JOB NO. 2945  
 ST. TIME 08/12 08:17  
 PGS. 1  
 SEND DOCUMENT NAME  
 TX IMCOMPLETE -----  
 TRANSACTION OK 3669537  
 ERROR -----

## BUILDING & SAFETY



DEVELOPMENT  
 SERVICES CENTER

DSC, Permits Division  
 731 South 4th Street  
 Las Vegas NV 89101  
 702-229-6251  
 702-474-7369 FAX  
 8AM to 5PM on Mon/Tue/Thu/Fri  
 8:30AM to 5PM on Wed

## PLAN READY NOTICE

**Total Fees Due: 125.00**

Date: 8/12/2010

To: APCO CONSTRUCTION @ 366 9537

Re: AP# 169109 REVISIONS

CITY OF LAS VEGAS MUSEUM

### Fee Breakdown

ADMIN	50.00
PLAN CHECK	75.00

**Building & Safety Fees Due: 125.00**

Your plans are ready to be picked-up. Please pull a ticket to see a cashier, and if paying by check, make it payable to the City of Las Vegas. MasterCard, Visa, and Discover credit/debit cards are also accepted. If you have any questions, please call the number above.

#### When picking-up a permit:

Licensed contractors must provide their:

- pre-printed company check or company credit card (company name must match license); **or**
- **if paying by any other means**, original Nevada State Contractors' Board card; **or**
- **if applicable**, authorized designee with a letter on company letterhead, signed by a principal of their company, specifically listing their designee's name, check number, and check amount.

Owner builders must provide their:

- proof of ownership (i.e., copy of deed to project property); **and**
- completed Nevada State Contractors' Board Owner Builder Affidavit of Exemption form; **and**
- **if applicable**, authorized designee with a notarized letter, signed by the property owner, specifically listing their designee's name and their permission to pick-up their permit.

**Photo ID is required**

**Cashiers Close at 4:30 PM.**

# BUILDING & SAFETY



DEVELOPMENT  
SERVICES CENTER

DSC, Permits Division  
731 South 4th Street  
Las Vegas NV 89101  
702-229-6251  
702-474-7369 FAX  
8AM to 5PM on Mon/Tue/Thu/Fri  
8:30AM to 5PM on Wed

## PLAN READY NOTICE

**Total Fees Due: 125.00**

Date: 8/12/2010

To: APCO CONSTRUCTION @ 366 9537

Re: AP# 169109 REVISIONS

CITY OF LAS VEGAS MUSEUM

### Fee Breakdown

ADMIN	50.00
PLAN CHECK	75.00

**Building & Safety Fees Due: 125.00**

Your plans are ready to be picked-up. Please pull a ticket to see a cashier, and if paying by check, make it payable to the City of Las Vegas. MasterCard, Visa, and Discover credit/debit cards are also accepted. If you have any questions, please call the number above.

#### When picking-up a permit:

Licensed contractors must provide their:

- pre-printed company check or company credit card (company name must match license); **or**
- **if paying by any other means**, original Nevada State Contractors' Board card; **or**
- **if applicable**, authorized designee with a letter on company letterhead, signed by a principal of their company, specifically listing their designee's name, check number, and check amount.

Owner builders must provide their:

- proof of ownership (i.e., copy of deed to project property); **and**
- completed Nevada State Contractors' Board Owner Builder Affidavit of Exemption form; **and**
- **if applicable**, authorized designee with a notarized letter, signed by the property owner, specifically listing their designee's name and their permission to pick-up their permit.

**Photo ID is required  
with all in-person transactions.**

**Cashiers Close at 4:30 PM.**